

# **Supplement to IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis**

Sponsor  
**Switchgear Committee  
of the  
IEEE Power Engineering Society**

Approved March 13, 1986  
**IEEE Standards Board**

Approved February 4, 1988  
**American National Standards Institute**

---

© Copyright 1988 by  
**The Institute of Electrical and Electronics Engineers, Inc**  
**345 East 47th Street, New York, NY 10017, USA**

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

# Supplement to IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis

*On page 21 of ANSI/IEEE C37.04-1979, add a note to the existing note of 5.10.3.3.1, Service Capability Duty Requirements, to read as follows:*

Circuit breakers having interrupting units that are hermetically sealed or otherwise designed such that normal maintenance procedures cannot be effected shall be capable of a number of operations in which the sum of the currents interrupted does not exceed 800% of the required asymmetrical interrupting capability at the operating voltage. The 800% capability may be demonstrated by an appropriate grouping of test duties from Table 1 or 2 of ANSI/IEEE C37.09-1979. Service capability requirements greater than 800% shall be subject to special agreement between manufacturer and user.